



RED FLAGS 2

© Copyright 2009 Front Line Chemicals, LLC.



Drip pan with a plugged drain is full of water.



A tipped pan will trap water.

WEEK 2: DRIP PANS

Drip Pans are a high risk for cross contamination. Overhead trapped moisture holds spoilage microorganisms.

RED FLAGS

Drain lines are plugged, drain lines plumbed half way to floor, drain lines are missing, drain lines plumbed into a cooling unit, drip pan tipped away from it's drain so the water cannot drain out, drip pan holding contaminated water directly over product and equipment. No written procedure for cleaning, sanitizing or inspecting drip pans exists or is being followed.

Drip pans don't have drain hose. Hoses not plumbed to floor.

Drip pans or trays should not be plumbed into cooling units.

**#1 GOAL:
A CLEANER PLANT**

AUDIT QUESTIONS

1. Are drip pans clean?
2. Are drip pans plumbed to drain properly?
3. Is overhead structure and piping clean?
4. After rotational cleaning, are we inspecting?
5. Are we documenting inspections?